



10'-0" MIN. WIDTH, CLEAR

FIRE DEPARTMENT APPROVED KEY ACCESS
MUST BE PROVIDED

GATE

2'-0" MIN.
SHOULDER

12'-0" MIN. ROAD SURFACE

2'-0" MIN.
SHOULDER

GATE

NOTE:
GATE WIDTH SHALL BE NO LESS THAN 10'-0"

GATE

FIRE SAFE STANDARDS

3/8" = 1'-0"

SCALE

REVISION DATE

MAY 15, 2009

6

DRAWING NO. 1

ST. HELENA FIRE DEPARTMENT

1480 MAIN STREET

ST. HELENA, CALIFORNIA 94574

TELEPHONE (707) 967-2792 FAX (707) 963-7748